

**CITY OF REEDLEY**  
**Reed Avenue Improvements**  
**Request for Interpretation of Contract Documents**

**Date:** June 15, 2016 **Time:** 2:15 PM  
**Company:** American Paving Co.  
**Contact Person:** Ross Jenkins  
**Address:** P.O. Box 4348, Fresno, CA 93744  
**Telephone:** 559-268-9886 **Fax:** 559-268-2908  
**Plan Sheet:** 2  
**Specification Section:** N/A


**INTERPRETATION REQUESTED:**

The typical cross sections on plan sheet 2 do not show the structural section of the Manning/Reed intersection.

Please provide a typical cross section for the Manning/Reed intersection.

REPLY:

According to the cross sections on Sheet X-1, FDR-C ends at Station 49+45, which is the south side of the intersection of Manning. From that Station north, new section is required. Use 0.58' HMA over 1.4' Class II Aggregate Base. These quantities are reflected in the Bid Items.



\_\_\_\_\_  
City Engineer

All request's and replies will be published on the City's web site at: [www.reedley.ca.gov](http://www.reedley.ca.gov) in addition to being faxed to plan holders.